

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 2440-1361:104 Page 1 of 1

CATEGORY: Insulation

LISTEE: Thermal Ceramics, P.O. Box 923, Augusta, GA 30903
Contact: Vicki Floyd (706) 796-4482 Fax (706) 560-4056

DESIGN: Type FireMaster® DuctWrap 2x2 and FireMaster® DuctWrap 2x2+ duct wrap insulation. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: Flame Spread: 5
Smoke Developed: 5

INSTALLATION: In accordance with the listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number and Omega Point Laboratory label.

APPROVAL: Listed as wall/ceiling insulation for use in building construction. May be used in attic and crawl spaces of combustible construction limited to entry for service of utilities when separate from all open space as required by applicable building standards.

NOTE: For through penetration applications, refer to CSFM Listing Category 4485-Opening Protection-Firestopping. For other applications, please consult the authority having jurisdiction for approval.

*Corrected 06-11-01



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 22, 2004**

*Listing Expires **June 30, 2005***

Authorized By: **DIANE K. AREND, Senior Deputy
Program Manager**